



CONCRETE
EQUIPMENT PAD

1. ALL METERS AND ISOLATION DEVICES ON PLAN WILL BE 24/7/365 ACCESSIBLE AND LOCKABLE.
2. NEW PV METER AND DISCONNECT MIGHT BE REQUIRED TO BE GROUPED WITH EXISTING METERING. FINAL METERING LOCATION AND GROUPING WILL BE DETERMINED BY THE NGRID METERING DEPARTMENT.
3. 20 FT ACCESSIBLE ROAD TO CONFIRM THE COMPANY PERSONNEL AND EQUIPMENT ACCESS REQUIREMENT ARE MET.

ISSUED FOR
IA



PROPOSED ROOF MOUNTED
SOLAR PV SYSTEM
SED - TOWN OF BOLTON LEACH
FIELD
692 MAIN ST
BOLTON, MA 01740

© (2021) Solvix Energy Development, LLC. All rights reserved.

SCALE	AS NOTED
DATE	12/9/2021
DRAWN BY	BF
CHECKED BY	

SHEET

PVSP-1



REVISIONS

NO.	DATE	DESCRIPTION	BY

ISSUED FOR
IA

PROPOSED ROOF MOUNTED
SOLAR PV SYSTEM
SED - TOWN OF BOLTON LEACH
FIELD
692 MAIN ST
BOLTON, MA 01740

© 2021 Solect Energy Development, LLC. All rights reserved.
This document contains the proprietary information of Solect Energy Development, LLC (Solect) and may not be modified, reproduced, retransmitted or redistributed without the written consent of Solect. Any unauthorized use of this document or any portion thereof without Solect's written consent may result in civil and criminal penalties.

89 Hayden Rowe Street, Suite E
Hopkinton, MA 01748 - (508) 598-3511

SCALE	AS NOTED
DATE	12/9/2021
DRAWN BY	BF
CHECKED BY	

SHEET
PVSP-2